

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WEST CARROLL)
WATER DISTRICT FOR A DEVIATION FROM)
THE REQUIREMENTS OF 807 KAR 5:066,)
SECTION 10(3), REGARDING SERVICE) CASE NO. 89-099
LINE INSPECTIONS, AND 807 KAR 5:066,)
SECTION 5(4), REGARDING WATER STORAGE)

O R D E R

By application received April 20, 1989, West Carroll Water District ("West Carroll") requested a deviation from 807 KAR 5:066, Section 5(4), and Section 10(3). These regulations require a water utility to provide water storage to ensure 1 day's supply of its average daily water usage, and to inspect service lines to ensure that the lines are free from any tees, branch connections, irregularities or defects.

Additional information is needed for an adequate and proper consideration of the deviation requested by West Carroll.

IT IS THEREFORE ORDERED that West Carroll shall file the original and seven copies of the following information with the Commission, with a copy to all parties of record, no later than May 26, 1989. If this information cannot be provided by this date, West Carroll should submit a motion for an extension of time stating the reason a delay is necessary and include a date by which it will be furnished. Such motion will be considered by the Commission. West Carroll shall furnish with each response the

name of the witness who will be available for responding to questions concerning each item of information requested should a public hearing be required in this matter.

1. Is the Department of Housing, Building and Construction or a local government agency conducting inspections of West Carroll's service lines to ascertain their compliance with the Kentucky State Plumbing Code?

2. According to its application, West Carroll's average daily usage is 1,421,826 gallons. How was this amount determined? Show mathematically how this amount was obtained.

3. How many water storage tanks does West Carroll have? List the capacity (in gallons) and location of each water storage tank.

4. How many water storage tanks do West Carroll's suppliers have? List the capacity (in gallons) and location of each water storage tank.

Done at Frankfort, Kentucky, this 15th day of May, 1989.

PUBLIC SERVICE COMMISSION


For the Commission

ATTEST:

Executive Director